



Last updated
01.12.2025

Lit candles and related products

Please note that lit candles are not permitted in the exhibition halls as a general rule.

Lit candles may be approved subject to certain requirements in agreement with the Fire Prevention Department of the Frankfurt Fire Brigade (as exhibits and/or with candle holders being exhibited).

These requirements are as follows:

1. For safety reasons, candles may only be used when placed behind glass (lanterns) or in containers filled with water (floating candles).
2. Lit candles or related products at the edge of the stand are forbidden. A minimum distance of 0.50 m from the edge of the stand must be maintained.
3. Candles must also be positioned carefully within the stand, to ensure that visitors do not inadvertently create a dangerous situation. A minimum distance of 0.50 m from flammable materials must be maintained.
4. For fire safety reasons, lit candles are not permitted in shelving.
5. A quantity appropriate for product presentation (2-3 candles) may not be exceeded.
6. The exhibitor / stand operator bears sole responsibility for any consequential damage. Messe Frankfurt Venue GmbH is not liable for any damage. By the start of setup latest, a responsible person must be named, including their full name and mobile phone number. This person must be present at the stand at all times, monitor the products and be able to initiate and implement the necessary measures in an emergency.

All Technical Guidelines are available for download on the Messe Frankfurt website:

<https://www.messefrankfurt.com/frankfurt/en/services.html#guidelines>

If you have any questions, please contact the Technical Event Management department at Messe Frankfurt, phone [+49 69 75 75-59 04](tel:+496975755904), E-Mail standapproval@messefrankfurt.com.